

QT - Bug #2270

Debian10.12-QT -qEhmi- - 2000 30 5

07/01/2022 02:53 PM - lz tang

Status:	New	Start date:	07/01/2022
Priority:	Normal	Due date:	
Assignee:	lz tang	% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:		Spent time:	0.00 hour

Description

The screenshot shows a SCADA system interface with a real-time alarm table and a search panel. The table lists various alarms with columns for time, station, description, system, priority, status, and confirmation. The search panel on the right allows filtering by station name, system, and device type.

报警产生时间	车站	报警描述	系统	优先级	状态	是否确	确认时	确认人	恢复时间	报警设备键
2022-07-01 14:48:25.883	横沥站	区间维修箱2仪表通讯故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	区间维修箱4断路器故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	区间维修箱4仪表通讯故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用断路器故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用仪表通讯故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用断路器故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用仪表通讯故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用断路器故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用仪表通讯故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用断路器故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:25.883	横沥站	备用仪表通讯故障 无信号	PSCADA	2级严重报警	未恢复	未...				HLS_IIPQA
2022-07-01 14:48:36.155	横沥站	33kV母联断路器状态 未定义	PSCADA	1级紧急报警	未恢复	未...				HLS_103_2
2022-07-01 14:48:36.155	横沥站	33kV站用变1断路器状态 未定义	PSCADA	1级紧急报警	未恢复	未...				HLS_104A
2022-07-01 14:48:36.155	横沥站	33kV站用变2断路器状态 未定义	PSCADA	1级紧急报警	未恢复	未...				HLS_104B

查询数量: 6775

快捷查询: 一级, 二级, 三级, 四级

过滤查询: 站名: 横沥站, 系统: 全部, 设备类型: 全部, 优先级: 全部

执行: 查询, 打印, 全部确认, 报文冻结

Files

200030.png	332 KB	07/01/2022	lz tang
------------	--------	------------	---------